

UNIVERSITY OF CALIFORNIA
FACILITIES AND CONSTRUCTION

Section:

Electrical/Electronics

Procedure: 4170

Condition: 0170

Frequency: 1

Priority: 1

Category: 1

Code: 1

Notes: 1

0170

See extension cords.

Procedure

Monthly:

1. Visually inspect.
2. Perform voltage test and record.
3. Submit all recordings and report any unusual conditions to the Electrical Manager.